AMENDMENT NO. 5 OCTOBER 2016
TO
IS 12709 : 1994 GLASS FIBRE REINFORCED PLASTIC (GRP) PIPES, JOINTS AND FITTINGS FOR USE FOR POTABLE WATER SUPPLY— SPECIFICATION

(First Revision)

(*Page* 5, *Table* 4) — Substitute the following table for the existing:

Table 5 Hydrostatic Test Pressures

Sl No.	**Pressure Class PN**	**Hydrostatic Test Pressure** kPa
(1)	(2)	(3)
i)	3	600
ii)	6	1 200
iii)	9	1 800
iv)	12	2 400
v)	15	3 000

(CED 50)

Publication Unit, BIS, New Delhi, India